

Energy performance certificate (EPC)

16 High Street
HYTHE
SO45 6AH

Energy rating

C

Valid until: 22 October 2031

Certificate number: 5626-2557-7780-1965-2479

Property type A1/A2 Retail and Financial/Professional services


Total floor area 53 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

24 A

If typical of the existing stock

71 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	79.06
Primary energy use (kWh/m ² per year)	468

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0825-4780-6310-0168-0775\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Peter Orchard
Telephone	02381661988
Email	info@allinonesurveys.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/016974
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Allinonesurveys Ltd
Employer address	Unit 3 The Works, 55 Millbrook Road East, Southampton SO15 1HN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	18 October 2021
Date of certificate	23 October 2021