

Energy performance certificate (EPC)

8 ASHFORD BUSINESS COMPLEX
166 FELTHAM ROAD
ASHFORD
TW15 1YQ

Energy rating

A

Valid until:

24 September 2030

Certificate number:

0632-3826-1900-9564-9603

Property type

B8 Storage or Distribution

Total floor area


379 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

40 B

If typical of the existing stock

117 E

Breakdown of this property's energy performance

Main heating fuel	Other
Building environment	Unconditioned
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	12.72
Primary energy use (kWh/m ² per year)	75

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0943-8716-0998-7745-7565\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jeremy Maltby
Telephone	+447920843616
Email	jeremy.maltby@ukesurveys.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/015691
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	UK Energy Surveys
Employer address	The Studio 22 Stanmore Lane Winchester SO22 4AJ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	6 August 2020
Date of certificate	25 September 2020
