

Energy performance certificate (EPC)

Unit 3 Viridian Park Pulborough Way HOUNSLOW TW4 6DE	Energy rating D	Valid until: 17 May 2031
		Certificate number: 2173-4230-6155-5351-2111

Property type

B8 Storage or Distribution

Total floor area

620 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

29 B

If typical of the existing stock

76 D

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Mechanical Ventilation
Assessment level	5
Building emission rate (kgCO2/m ² per year)	50.97
Primary energy use (kWh/m ² per year)	301

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/1558-5930-7319-6479-9781\)](#).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Walton
Telephone	07515 329 786
Email	mark.walton@meessolutions.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	CIBSE Certification Limited
Assessor's ID	LCEA181643
Telephone	020 8772 3649
Email	epc@cibsecertification.org

About this assessment

Employer	MEES Solutions Limited
Employer address	85 Great Portland Street, First Floor, London W1W 7LT
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	15 February 2021
Date of certificate	18 May 2021