

Energy performance certificate (EPC)

SUITE 1, FIRST FLOOR
Barry House
20-22 Worpole Road
LONDON
SW19 4DH

Energy rating

D

Valid until: **23 May 2028**

Certificate number: **0398-0138-8589-6495-7002**

Property type

B1 Offices and Workshop businesses

Total floor area


120 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is D.



Properties are also given a score. The larger the number, the more carbon dioxide (CO₂) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

34 | B

If typical of the existing stock

100 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	60.41
Primary energy use (kWh/m ² per year)	357

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0796-9158-8440-3500-9883\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Daniel Montlake
Telephone	02071834885
Email	dan@coresustainability.com

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO028472
Telephone	0330 124 9660
Email	certification@stroma.com

Assessment details

Employer	Core Sustainability
Employer address	Kemp House, 152 City Road, London, EC1V 2NX
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 May 2018
Date of certificate	24 May 2018
