

Energy performance certificate (EPC)

54 Station Road
South Gosforth
NEWCASTLE UPON TYNE
NE3 1QD

Energy rating

E

Valid until:

10 December 2035

Certificate number:

6812-3325-1218-0113-8836

Property type

Retail/Financial and Professional Services

Total floor area


78 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

18 A

If typical of the existing stock

73 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	42.37
Primary energy use (kWh/m ² per year)	255

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0280-1442-4419-6863-9211\)](/energy-certificate/0280-1442-4419-6863-9211).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Kevin Anderson
Telephone	07895376158
Email	kmander7123@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019511
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Kevin Anderson
Employer address	kmander7123@gmail.com
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	8 December 2025
Date of certificate	11 December 2025
