

Air conditioning inspection certificate

Santander
20 Stepney Street
Llanelli
SA15 3UR

Certificate number
7061-4910-9674-2264-6807

Valid until
2 December 2029

Assessment details

Inspection date	3 December 2024
Inspection level	Level 3
Assessment software	ACE Wizard, V1.0
Assessor's declaration	Not related to the owner/occupier or person who has technical control of the system or subcontractor.
F-Gas compliant date	Not Provided
Total effective rated output	28 kW
System sampling	Yes
Treated floor area	178 square metres
Subsystems metered	No
Total estimated refrigerant charge	11 kg

Inspection report

For the assessor's recommendations, [see the inspection report \(/energy-certificate/6356-5930-1124-5414-0142\)](/energy-certificate/6356-5930-1124-5414-0142).

Subsystems inspected

Subsystem ID	Description	Refrigerant type	Age of main components
VOL001/SYS001 Whole Building	1 Daikin VRV System Serving Whole Building	R410A	17 years

Assessor's details

Assessor's name	Richard Brown
Email	info@greenzonesurveys.com
Assessor ID	EES/029946
Employer/Trading name	Green Zone Surveys (UK) Ltd
Employer/Trading address	Second Floor, Cobalt Business Exchange, Cobalt Park Way, Newcastle Upon Tyne NE28 9NZ
Accreditation scheme	Elmhurst Energy Systems Ltd
Accreditation scheme telephone	01455 883 250
Accreditation scheme email	enquiries@elmhurstenergy.co.uk
