Energy performance certificate (EPC)

Victoria Building Victoria Park Lerret Road PORTLAND DT5 1GB	Energy rating **E**	Valid until: **23 January 2034** Certificate number: **4900-0860-4891-6137-7606**


Property type	Offices and Workshop Businesses
Total floor area	868 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	41 B
If typical of the existing stock	165 G

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	39.37
Primary energy use (kWh/m2 per year)	228

Recommendation report

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/4683-8100-4214-0952-3759).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jeremy Maltby
Telephone	01962861555
Email	jeremy.maltby@ukesurveys.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/015691
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	UK Energy Surveys
Employer address	The Studio 22 Stanmore Lane Winchester SO22 4AJ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	16 January 2024
Date of certificate	24 January 2024