

Energy performance certificate (EPC)

1-3 Hospital Street
NANTWICH
CW5 5RH

Energy rating

C

Valid until: 20 August 2030

Certificate number: 0980-6251-0300-6430-3060

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


150 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

29 B

If typical of the existing stock

86 D

Breakdown of this property’s energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	71.48
Primary energy use (kWh/m2 per year)	421

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/2666-4038-0500-0300-4191\)](/energy-certificate/2666-4038-0500-0300-4191).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Timothy Havard
Telephone	07580978368
Email	oakbrookconsultants@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/010360
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	The Oakbrook Consultancy
Employer address	20 Richard Moon Street, Crewe, Cheshire, CW1 3AX
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	14 August 2020
Date of certificate	21 August 2020
