

# Energy performance certificate (EPC)

1b Dalton Street  
HULL  
HU8 8BB

Energy rating

**E**

Valid until: **3 September 2028**

Certificate number: **9222-3006-0084-0200-3425**

Property type

B1 Offices and Workshop businesses

Total floor area

182 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.


If a property has an energy rating of F or G, the landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

## Energy efficiency rating for this property

Properties are also given a score. The larger the number, the more carbon dioxide (CO<sub>2</sub>) your property is likely to emit.

This property's current energy rating is E.



## How this property compares to others

Properties similar to this one could have ratings:

If newly built

22 | A

If typical of the existing stock

65 | C

Properties are given a rating from A+ (most efficient) to G (least efficient).

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	35.33
Primary energy use (kWh/m <sup>2</sup> per year)	209

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0320-0248-2049-2026-4006\)](#).

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	Matt Penrose
Telephone	01482 845452
Email	<a href="mailto:matt@penroseconsulting.co.uk">matt@penroseconsulting.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/008648
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### Assessment details

Employer	PPH Commercial
Employer address	The Hesslewood Estate, Ferriby Road, Hessle, HU13 0LG
Assessor's declaration	The assessor is employed by the organisation dealing with the property transaction.
Date of assessment	27 June 2018
Date of certificate	4 September 2018

---