

Energy performance certificate (EPC) recommendation report

Assendun Works
Lower Road
HOCKLEY
SS5 5LD

Report number
**6622-2042-0669-0277-
4645**

Valid until
18 June 2036

Energy rating and EPC

This property's energy rating is C.

For more information on the property's energy performance, [see the EPC for this property \(/energy-certificate/2775-6871-7200-7466-3338\)](/energy-certificate/2775-6871-7200-7466-3338).

Recommendations

Changes that may pay for themselves within 3 years

Recommendation

In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.

Potential impact on carbon emissions

Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation

Consider replacing T8 lamps with retrofit T5 conversion kit.

Potential impact on carbon emissions

High

Changes that may pay for themselves in over 7 years

Recommendation

Potential impact on carbon emissions

Recommendation	Potential impact on carbon emissions
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	Low
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium
Consider installing building mounted wind turbine(s).	Low
Consider installing solar water heating.	Low

Property and report details

Report issued on	19 June 2026
Total useful floor area	296 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	CLG, iSBEM, v6.1.e, SBEM, v6.1.e.0

Assessor's details

Assessor's name	John Elson
Telephone	07905 017383
Email	johne921@gmail.com
Employer's name	<insert Employer/Trading Name>
Employer's address	<insert Employer/Trading Address>
Assessor ID	EES/013083
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd

Other reports for this property

If you are aware of previous reports for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related reports for this property.




[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](#)

OGI

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



© [Crown copyright \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/)