

Energy performance certificate (EPC)

Unit 4 Millbuck Park
Millbuck Way
Springvale Industrial Estate
Sandbach
CW11 3HT

Energy rating

C

Valid until: 15 February 2032

Certificate number: 6120-7547-7923-0499-6129

Property type

B1 Offices and Workshop businesses

Total floor area

541 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

30 B

If typical of the existing stock

88 D

Breakdown of this property’s energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	28.01
Primary energy use (kWh/m2 per year)	163

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/8408-2699-3912-2519-5005\)](/energy-certificate/8408-2699-3912-2519-5005).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Brett Carroll
Telephone	01925 387 550
Email	info@cpsurveyors.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/008107
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Cheshire Property Surveyors
Employer address	Suite 2 11 Eagle Brow Lymm WA13 0LP
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	3 February 2022
Date of certificate	16 February 2022
