

# Energy performance certificate (EPC)

1149 New Chester Road  
EASTHAM  
CH62 0BY

Energy rating

**B**

Valid until:

**23 September 2034**

Certificate number:

**5108-6908-5408-2051-9028**

Property type

Restaurants and Cafes/Drinking  
Establishments/Takeaways

Total floor area


54 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

13 A

If typical of the existing stock

52 C

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	86.76
Primary energy use (kWh/m <sup>2</sup> per year)	916

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/6079-5605-8285-3618-3154\)](/energy-certificate/6079-5605-8285-3618-3154).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Dean Ware
Telephone	07540 403 069
Email	<a href="mailto:info@deanalexanderenergy.com">info@deanalexanderenergy.com</a>

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/027382
Telephone	01455 883 250
Email	<a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a>

### About this assessment

Employer	Dean Alexander Energy Consultants Limited
Employer address	Office B12B, 23 Goodlass Road, Liverpool, L24 9HJ
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 September 2024
Date of certificate	24 September 2024

---