

Energy performance certificate (EPC)

Building 1
Jewson
Outgang Lane
Dinnington
S25 3QY

Energy rating

B

Valid until:

17 March 2036

Certificate number:

0652-4497-2789-2703-0748

Property type

Retail/Financial and Professional Services

Total floor area

1,506 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

14 A

If typical of the existing stock

56 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	11.82
Primary energy use (kWh/m ² per year)	98

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4968-2300-2725-7710-7613\)](/energy-certificate/4968-2300-2725-7710-7613).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Jason N Lile
Telephone	01604676005
Email	jason@epcpartnership.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/019993
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	BakerLile - www.epcpartnership.com
Employer address	BakerLile 10 The Choakles Wootton Northampton NN4 6AP
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	24 February 2026
Date of certificate	18 March 2026